

Certificate of Analysis



Report Number: **COV/2833940/2025**

Issue **1**

Laboratory Number **25275145**

Sample **3** of **8**

Sample Source: **Gwynedd County Council**

Sample Point Description: **Water Analysis**

Sample Description: **MW/0525/19**

Sample Matrix: **Not Specified**

Sample Date: **15 May 2025**

Sample Received: **15 May 2025**

Analysis Complete: **29 May 2025**

Test Description	Result	Units	Limit	Accreditation		Method
Clostridium Perfringens, Pres	1	cfu/100ml	0	N	Cov	W8
TVC 37C 2 day	1	cfu/ml		N	Cov	W1
TVC 22C 3 day	21	cfu/ml		N	Cov	W1
Total Coliform presumpt	0	cfu/100ml	0	N	Cov	W10
Total Coliforms confirmed	0	cfu/100ml	0	N	Cov	W10
E.coli presumptive	0	cfu/100ml	0	N	Cov	W10
Escherichia coli confirmed	0	cfu/100ml	0	N	Cov	W10
Enterococci presumptive	0	cfu/100ml	0	N	Cov	W7
Enterococci confirmed	0	cfu/100ml	0	N	Cov	W7
Clostridium Perfringens, Conf	0	cfu/100ml	0	N	Cov	W8

Analyst Comments for 25275145:

No Analyst Comment

This issue replaces all previous issues

Accreditation Codes: Y = UKAS / ISO17025 Accredited, N = Not UKAS / ISO17025 Accredited, M = MCERTS.

Analysed at: Che = Chester(CH5 3US), Cov = Coventry(CV4 9GU), S = Subcontracted, Trb = Subcontracted to Trowbridge(BA14 0XD), Wak = Wakefield(WF5 9TG), F = Data supplied by customer.

For Microbiological determinands 0 or ND=Not Detected, For Legionella ND=Not Detected in volume of sample filtered.

I/S=Insufficient sample For soil/sludge samples: AR=As received, DW=Dry weight.

ALS Laboratories (UK) Limited

Torrington Avenue, Coventry, CV4 9GU Tel: +44 (0)24 7642 1213